

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3230-0245:116 Page 1 of 1

CATEGORY: Leakage Dampers

LISTEE: Ruskin Manufacturing, 3900 Dr. Greaves Road, Grandview MO 64030
Contact Person: Robert Van Becelaere (816) 761-7476

DESIGN: Model FSD60-FA leakage rated damper. Single and multiple blades type construction. Unit consist 16 Ga. galvanized steel frame, 22 Ga. galvanized steel blade and a listed power operator. Refer to listee's data sheet for detailed product description and operational considerations.

<u>Width, inches</u>		<u>Height, inches</u>	
Min.	Max.	Min.	Max.
18"	48"	12"	49"

RATING: Class I-350

INSTALLATION: In accordance with the listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, rating and UL label.

APPROVAL: Listed as Class I leakage damper.

05-11-01



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

MAY 15, 2002

*Listing Expires **June 30, 2003***

Authorized By:

BDIANE K. AREND, Senior Deputy
Program Manager